

P91 1-3kVA Extended Runtime Chart
Estimated Minutes

March 13, 2026

UPS Load (W)	200	300	400	500	900	1350	1800	2700
P91-1000	32	19	13	9	3	N/A	N/A	N/A
P91-1500	54	32	22	16	7	3	N/A	N/A
P91-1500 + 1 BP36	197	124	92	68	32	19	N/A	N/A
P91-1500 + 2 BP36	375	223	158	124	61	36	N/A	N/A
P91-1500 + 3 BP36	529	336	237	181	95	56	N/A	N/A
P91-1500 + 4 BP36	691	465	320	245	124	80	N/A	N/A
P91-1500 + 5 BP36	855	556	424	312	154	99	N/A	N/A
P91-1500 + 6 BP36	1020	664	500	396	188	120	N/A	N/A
P91-1500 + 7 BP36	1188	772	569	465	223	137	N/A	N/A
P91-1500 + 1 BP36E	375	223	158	124	61	36	N/A	N/A
P91-1500 + 2 BP36E	691	465	320	245	124	80	N/A	N/A
P91-1500 + 3 BP36E	1020	664	500	396	188	120	N/A	N/A
P91-1500 + 4 BP36E	1356	882	650	518	260	159	N/A	N/A
P91-1500 + 5 BP36E	1697	1104	813	642	336	205	N/A	N/A
P91-1500 + 6 BP36E	2042	1328	979	772	429	253	N/A	N/A
P91-1500 + 7 BP36E	2390	1555	1146	904	496	303	N/A	N/A
P91-2000	80	46	32	24	11	6	3	N/A
P91-2000 + 1 BP48	278	171	124	98	46	27	19	N/A
P91-2000 + 2 BP48	510	316	223	171	91	53	36	N/A
P91-2000 + 3 BP48	718	481	336	256	128	84	56	N/A
P91-2000 + 4 BP48	937	610	465	352	171	111	80	N/A
P91-2000 + 5 BP48	1160	754	556	455	217	133	99	N/A
P91-2000 + 6 BP48	1384	900	664	526	266	163	120	N/A
P91-2000 + 7 BP48	1611	1048	772	610	316	194	137	N/A
P91-3000	124	80	54	40	19	11	7	3
P91-3000 + 1 BP72	465	278	197	150	80	46	32	19
P91-3000 + 2 BP72	772	510	375	278	137	91	61	36
P91-3000 + 3 BP72	1104	718	529	433	205	128	95	56
P91-3000 + 4 BP72	1441	937	691	545	278	171	124	80
P91-3000 + 5 BP72	1783	1160	855	674	363	217	154	99
P91-3000 + 6 BP72	2129	1384	1020	805	448	266	188	120
P91-3000 + 7 BP72	2478	1611	1188	937	510	316	223	137

For detailed runtime data, refer to the P91 1–3kLi Flyer
<https://xpcc.com/wp-content/uploads/P91-1-3kVA-Flyer.pdf>