

P91 5-10kVA Extended Runtime Chart
Estimated Minutes

March 16, 2026

Load in W		500	1000	1500	2000	2500	3000	3500	4000	5000	6000	7000	8000	9000	10000
BPXR2U240A	1 BP	66	53	35	27	20	15	13	11	7	5.3	4.4	3.9	3.4	2.2
	2 BP	132	117	81	61	47	38	32	27	20	15	13	11	9	7
	3 BP	212	171	123	100	76	62	51	43	33	27	22	18	15	13
BPXR3U240A	1 BP	112	92	62	46	35	29	24	20	15	12	10	8	7	6
	2 BP	223	182	128	106	82	66	55	47	36	29	24	20	18	15
	3 BP	351	287	197	151	124	107	90	76	58	47	39	33	29	25
	4 BP	484	395	272	208	163	134	120	107	83	66	55	47	41	36
	5 BP	621	507	349	267	209	172	145	128	107	87	72	61	53	47
	6 BP	761	621	428	327	257	211	177	153	124	107	90	76	66	58
	7 BP	904	738	508	388	305	250	211	182	142	122	107	92	80	70
	8 BP	1050	857	590	451	354	291	245	211	164	134	120	107	94	83

For detailed runtime data, refer to the P91 5–10k Flyer
<https://xpcc.com/wp-content/uploads/P91-5-10kVA-Flyer.pdf>